



Certificate of Test: Chilt/P08124/03

This certificate is awarded to:

The Folding Sliding Door Company Ltd

FSD Works
Hopbine Avenue
West Bowling
Bradford
West Yorkshire
BD5 8ER

This document confirms that performance testing was conducted on 12 November 2008. Testing was conducted to the following standard;-

- BS 6375 Part 1:2004 Performance of windows and doors - Part 1: Classification for weathertightness and guidance on selection and specification. The following results were achieved

Product tested	FD68 Laminated Oak Bi-folding doorset (Inward opening)		
Summary of testing procedure			Result
	Test Standard	Classification Standard	
Air permeability	BS EN 1026: 2000	BS EN 12207: 2000	300pa (Class 2)
Watertightness	BS EN 1027: 2000	BS EN 12208: 2000	300pa (Class 7A)
Wind resistance	BS EN 12211: 2000	BS EN 12210: 2000	800pa (Class A2)
Exposure category	BS 6375: Part 1: 2004		800

Air leakage at 50pa was 5.9m³/h positive pressure and 4.9m³/h negative pressure. The perimeter length of opening light was 11.82m.

The results relate only to the specimen tested, as detailed in the technical specification Chilt/P08124/tec3

S.S. Smith

Steve Smith – Test Engineer

Date: 13-05-2009

Vincent Kerrigan

Vincent Kerrigan – Technical Manager

Date: 13-05-2009

Chiltern Dynamics

Chiltern House, Stocking Lane, Hughenden Valley, High Wycombe, HP14 4ND, United Kingdom

Tel: 01494 569800 Fax: 01494 564895

Web: www.chilternfire.co.uk

Email: cif@chilternfire.co.uk

Page 1 of 4



1762